



eurofins

Attestation

Eurofins Product Testing A/S received a sample of an adhesive with the name

WAKOL PU 225 Parkettklebstoff Wakol GmbH

The emissions were tested in the style of the method "Testing of volatile organic emissions from various sources using small-scale environmental chambers" as defined in the California Specification Section 01350 (CA/DHS/EHLB/R-174) - Version of July 15, 2004, see test report no. 760464.

Testing was already performed after 3 days.

Evaluation of the test result according to CA 01350/FloorScore guidelines:

- No carcinogens and reproductive/developmental toxins could be detected.
- No individual VOC exceeds one-half of the lowest concentration of interest in a building (chronic REL).
- Formaldehyde concentration does not exceed one-half of the lowest concentration of interest in a building (indoor REL).

The tested product complies with the requirements of California Specification Section 01350 (CA/DHS/EHLB/R-174) - Version of July 15, 2004 when tested after 3 days.

23.03.2010

Thomas Neuhaus
Head of product emission test centre

Martin Møller Pedersen
M.Sc. (Pharm.)

Eurofins Product Testing A/S
Smedeskovej 38
DK-8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75